

**SERIES 9003 (WINDOW WALL)
THERMALLY BROKEN ALUMINIUM
CASEMENT / AWNING / FIXED**



SPECIFICATION

I. GENERAL.

Aluminium windows shall be Starline 9003 Window Wall Series
Manufactured by: Starline Architectural Windows Ltd.
Head office: 9380 – 198th Street, Langley, B.C. V1M 3C8

APPLICATION

A high-quality completely thermally broken 4 ½” aluminum casement/awning/fixed window with seismic jambs, designed for residential high-rise construction.
This series is available with push out casement, top hung awning, and fixed configurations. Standard design comes complete with seismic jambs, with 46mm triple glazed igu and with white extruded PVC glazing stops.

DESCRIPTION

Work included: Furnish labor, material and other services to complete the fabrication and installation of the windows, including all materials and fitments required for the operation of the units in the manner, direction and performance shown on the shop drawings and specified herein.
Work not included: Structural support of window framing, interior trims. (Specifier list others).
Related work specified elsewhere: (Specifier list).

QUALITY ASSURANCE

Drawings and specifications for work of this section are based upon 9003 Windows as manufactured by Starline Architectural Windows Limited. Whenever alternative products are offered, submit supporting technical literature, samples, drawings and performance data for comparison 10 days prior to closing date.

TESTING AND PERFORMANCE

(Specifier to select the performance requirements from the following options)

1. Limit mullion deflection to L/175.
Independent testing facility shall verify maximum deflection on minimum two window panels selected by the consultant prior installation.
2. Allow for deflection of building structure. Aluminum window frames with head deflection channel and seismic compensation jamb channel shall be designed, fabricated and installed to withstand slab edge vertical differential deflections of maximum 3/4” and seismic inter-story lateral drift movements of Delta S +/- 3/4” without significant damage to the fenestration system or Delta M +/- 2 1/2” with significant damage expected but framing to be designed to remain anchored to the structure.
Or
Allow for deflection of building structure. Aluminum window frames with head deflection channel and seismic compensation jamb channel shall be designed, fabricated and installed to withstand slab edge vertical differential deflections of maximum 3/4” and seismic inter-story lateral drift movements of +/- 3/4” without significant damage to the fenestration system or +/- 2 1/2” with significant damage expected but framing to be designed to remain anchored to the structure.
3. There shall be no water infiltration for fixed windows when tested in accordance with ASTM E547-00 and ASTM E331-00 with a pressure difference of 10.4 PSF/ 500 Pa (Field test).
Or
Fixed window water tightness shall meet the B5 rating (Field Test, no water leakage at 10.4 PSF (500Pa)) when tested in accordance with CAN/ CSA-A440-98 windows.

MAINTENANCE AND GUARANTEE

Provide data for maintenance and cleaning in accordance with instruction under general conditions.
Provide a written guarantee for the complete installation provided under this section against defective material and workmanship, which appears within a period of two years from the date of substantial completion.

**SERIES 9003 (WINDOW WALL)
THERMALLY BROKEN ALUMINIUM
CASEMENT / AWNING / FIXED**



II. PRODUCTS

MATERIAL

Frame member and intermediate bars are extruded from aluminum sections of 6063 alloy, T5 temper with a minimum thickness of 0.064". Fastener shall be stainless steel of sufficient size and quantity to perform their intended function.

Weathering and glazing gaskets shall be extruded santoprene or EPDM.

Exterior glazing tape shall be Tremco Polyshim II.

Glass Setting Blocks & Edge Blocks shall be FPVC, Neoprene, EPDM, Santoprene or silicone with an 80 to 90 ± Shore A durometer hardness. Block material shall be compatible with sealed unit edge sealant. Setting blocks for sealed units with silicone edge seals must be silicone.

Heel bead shall be silicone GE SCS 2800.

Glazing bead shall be extruded PVC or extruded aluminum.

Thermal break shall be Polyamide.

FINISH (POWDER COATING)

All exposed surfaces of aluminum window and framing members shall be free of scratches and other serious surface blemishes.

Standard

1. Interpon® D1010 thermosetting coating specifically designed for Architectural Systems that meets the AAMA 2603-02 specification that covers pigmented organic coatings on aluminum extrusions. Standard color is Standard White (GA104Q).

Option

1. Interpon® D3000 thermosetting fluorocarbon coating specifically designed for Architectural Systems that meets the AAMA 2605-02 specification that covers pigmented organic coatings on aluminum extrusions. The AAMA 2605-02 specification demands advanced levels of weather resistance, combined with excellent chemical, mechanical and anti-corrosion performance along with the maximum gloss and color retention.
2. The following semi standard colors are available:
 - Beige
 - Black Charcoal
 - Bronze
 - Graphite Grey
 - Gray Velvet
 - Grey Charcoal
 - Hartford Green
 - Iron Mountain Gray
 - Light Bronze
 - Metal Shavings Grey
 - Sea Wolf Gray
 - Standard Black
 - Standard Brown
 - Standard Silver
 - Terra Cotta

FABRICATION

Fabricate framing from extrusions of size and shape shown on shop drawings. Interior and exterior extruded aluminum framing sections shall be integrated with a Polyamide thermal break to form a rigid composite assembly without the use of fasteners or other thermal bridging elements. Dry shrinkage of polyamide thermal break shall not exceed 0.10% of the framing member length.

Main framing shall be designed for butt corner construction. Operating sash extrusions shall be mitred corner construction.

All framing joints shall be accurately machined, assembled and sealed to provide neat water- and airtight connection. Coupling mullions shall be designed to provide a functional split to permit modular construction and allow for thermal expansion.

All frame corners are mechanically joined by stainless steel screws. All interior joints and interior screw heads shall be sealed with a non-hardening sealant. Ventilators shall be double weather stripped with black santoprene bulb seal weather-stripping for the full perimeter at the interior and exterior of the ventilator.

All glazing pockets shall be vented, pressure equalized and drained to the vertical extrusions.

Glass bead shall be snap-in screw less type. Silicone heel bead shall be applied at the perimeter of all insulated glazing units.

**SERIES 9003 (WINDOW WALL)
THERMALLY BROKEN ALUMINIUM
CASEMENT / AWNING / FIXED**



GLAZING

The 9003 series aluminum windows shall be triple glazed, double seal insulated glass unit with an overall thickness of 1 3/4" (46 mm). Glass thickness and quality shall conform to the requirements of the U.S.A. and Canadian Code for commercial construction, current edition. Minimum glass thickness shall be 4mm.

HARDWARE

Push out ventilators shall be hung on concealed heavy duty stainless steel four bar friction hinges with adjustable friction shoe. Hinges are completely concealed when ventilator is in its closed position. Metal cam handle shall lock positively against the mounted keeper and are available as a standard in black and white. Mounted keeper shall be black or white PVC.

All vents shall be restricted with restrictor plates to 4".

Note: Roto operators are not available on this series.

OPTIONAL ITEMS

(Specifier to select from the following options)

1. Glazing – Tempered, tinted & reflective, LowE performance coating, laminated glass, obscure, (spandrel glass is not available)
Stainless steel spacer bars, dark bronze aluminum spacer bar,
2. Coupling mullions – wide range of couplers are available (all thermally broken) to suite a variety of configurations i.e.: 180, 90
3. Deflection channel, bypass
4. Separate colours on the inside & outside

SCREENS (OPTIONAL)

Insect screen frames shall be extruded aluminum finished to match interior window frame color and rigidly joined at the corners. Screen shall be black fibre mesh. Screens are held in place with PVC clips.

III. EXECUTION

INSTALLATION

Windows shall be installed, glazed and adjusted by experienced personnel in accordance with the manufacturer instructions and approved shop drawings. All items in this section shall be set in their correct location and shall be set level, square, plumb and at proper elevations and in alignment with other work.

PROTECTION AND CLEANING

Aluminum shall be isolated from concrete, mortar, plaster and dissimilar metals with bituminous paint or other isolation coatings. It shall be the responsibility of the general contractor to maintain protection and provide final cleaning.

**Laws, building and safety codes governing the design and use of this product vary widely.
Starline Architectural Windows Ltd. does not control the selection
And use of this product and assumes no responsibility therefor.**